

ATTESTATION OF CONFORMITY

TO ENEL DISTRIBUZIONE SPA DK 5940 SPECIFICATIONS

ATTESTATO DI CONFORMITA'

ALLE SPECIFICHE DK 5940 ENEL DISTRIBUZIONE SPA

Attestation number
Attestazione numero : **350060000**
Issued to
Rilasciata a : **Danfoss Solar Inverter A/S**
: **Jyllandsgade 28**
: **DK-6400 Soenderborg**
: **DENMARK**

Manufacturer
Costruttore : **Danfoss Solar Inverter A/S**
: **Jyllandsgade 28**
: **DK-6400 Soenderborg**
: **DENMARK**

Product Type
Tipo prodotto :

Interface Device <i>Dispositivo Interfaccia</i>	Interface Protective Device <i>Dispositivo protezione interfaccia</i>	Static Conversion Device <i>Dispositivo di conversione statico</i>
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>

Model reference
Riferimento Modello :

TLX 10K
TLX 12.5K
TLX 15K

Software release
Revisione software : **1.0**

Testing Laboratory
Laboratorio prove : **Euro Test Laboratori S.r.L., Via dell'Industria 18 – 35020 Brugine (PD), ITALY**
(SINAL Accreditation No. 0192)

Test Report ref. No.
Rapporto di prova Nr. : **DK 01 CdO 08C265002 issued by Euro Test Laboratori S.r.L.;**
DANAK 19K0534 issued by DELTA Laboratory; 08/213-01 issued by SHARP EMC Testing
Lab (Hamburg).

Requirements
Requisiti : Technical Specification DK 5940 (Ed. 2.2, April 2007), issued by ENEL DISTRIBUZIONE
SPA
Specifiche tecniche DK 5940 (Ed. 2.2, April 2007) emesse da ENEL DISTRIBUZIONE SPA

The undersigned declares that the above described product meets the above mentioned technical specification. This attestation of conformity is issued based on the test results as laid down in the referred Test Report by Euro Test Laboratori S.r.L.. The investigation does not include an assessment of the manufacturer's production.

Il sottoscritto dichiara che il prodotto di cui sopra è conforme ai requisiti tecnici menzionati. Questo attestato di conformità è rilasciato sulla base dei risultati di prova riferiti nel rapporto di Euro Test Laboratori sopra menzionato.

La valutazione non include una verifica del luogo di produzione.

A handwritten signature in black ink, appearing to read "F. Vasta".

Date of issue
Emesso in data : 2008-09-30

Franco Vasta

Certification Manager

KEMA QUALITY B.V. is EN 45011:1998 and ISO/IEC Guide 65:1996 accredited by the Dutch Accreditation Council (RvA).
Accreditation certificate Number C 001, valid until April 7, 2010.

KEMA QUALITY B.V. è accreditata dal Dutch Accreditation Council (RvA) in accordo a EN 4501:1998 e ISO/IEC Guida 65:1996. Certificato di Accreditemento numero C 001, valido fino al 7 Aprile 2010.